

SAP 07-601-13

4/3/2015

Q1: Regarding salvage topsoil in areas where you are showing a cut in the back slope that extends to the R/W line, where are you envisioning storing the topsoil when we cut out the back slope.....typically there is a temp easement behind these areas for topsoil storage....?

A1: We expect the contractor to store the salvaged topsoil at the outside of the ROW within the detailed ROW. There are no additional easements beyond those shown in the project plans.

Q2: For common borrow – if we were to obtain from other source(s), would you still cross section & pay for?

A2: Blue Earth County has already contracted and paid for the estimated borrow material for the project at the designated sight.